



Government of Tripura  
Directorate of Fire & Emergency Services  
Tripura, Agartala.

Phone: 0381-2326451 Fax: 0381-2324826. Email: [dfireservicetripura@gmail.com](mailto:dfireservicetripura@gmail.com). Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No. 3-8/TFES/2021/ 7791-93

Dated, Agartala, the 16<sup>th</sup> September, 2021.

To  
The Administrator,  
Siksha Bhavan Montessori School,  
Shibbari Road, Baruakandi,  
Dharmanagar, North Tripura.  
Ph. No. 9862729251/8732882110.

Subject: - Issuance of Fire NOC.

Sir,

With reference to the letter No. nil dated 28.07.2021, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 26.08.2021. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. Therefore, the premises/building is issued Temporary NOC with effect from 16/09/2021 for a period of 03 (three) months subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building/premises:- Siksha Bhavan Montessori School, Shibbari Road, Baruakandi, Dharmanagar, North Tripura.

Issued on 16/09/2021 at Agartala.

**N.B.** Department is switching over offline issuance of NOC to online shortly. Therefore provisional / Temporary NOC is issued for a period of 03 (three) months.

Yours faithfully,

  
16/08/21  
Joint Director,

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:-

1. The Divisional Fire Officer, Unakoti District, Kailashahar, Tripura for favour of information.
2. OC, Dharmanagar F&ES Station for information.